

Sr. No.	Genset Rated →	10kVA - Mech
A	Genset specification ↓	
1	Genset rating	Prime
2	Genset output (kVA/kWe)	10 / 8
3	Genset model	GPWII-PIV- 10M
4	Gross engine Power (kWm)	11
5	Gross engine Power (HP)	15
6	Engine model	G12-IV
7	Aspiration / Cooling	Water cooled
8	No. of Cylinders / Arrangement	2 / inline
9	Displacement (L)	1.56
10	Bore x Stroke (mm)	95 X 110
11	Compression ratio	17.5
12	Rated RPM	1500
13	Overspeed trip (RPM)	1650
14	Governor type / DG Performance Class	Mech / G2
15	Frequency Regulation	Isochronous
16	Air cleaner type / Qty	Dry / 01
B	Exhaust system	
1	Max allowable backpressure before After-treatment (kPa)	7
2	Max allowable backpressure post After-treatment (kPa)	5
3	Exhaust temperature (Deg C)	550
4	Silencer type	Residential
5	Aftertreatment System	NA
C	Engine electrical system	
1	Charging alternator VDC / Amps	12V / 35 A
2	Starter motor rated voltage (DC)	12
3	Battery voltage (DC) / Capacity (AH)	12V / 88 AH
D	Fuel System	
1	Recommended fuel	IS 1460, HSD
2	Fuel tank capacity (L)	30
E	Fuel Consumption @ % load (LPH)(Including radiator fan + other accessories)⁽¹⁾	
1	LPH @ 100%	3.1
2	LPH @ 75%	2.4
F	Lubricating Oil System	
1	Lube oil sump capacity (L)	5.5
2	Lube oil change period (Hrs)	500
3	Lube oil consumption (% of SFC)	≤0.1%
4	Lube oil filter type / Qty	Spin on / 01
5	Recommended lube oil grade	15W40, API CI4+
6	Recommended lube oil	Greaves Maxtherm

GREAVES COTTON LIMITED

Email ID: info@greavescotton.com Website: www.greavescotton.com

Registered Office: J-2, MIDC Industrial Area, Chikalthana, Aurangabad - 431210, India

Corporate Office: Unit No.1A, 5th Floor, Tower 3, Equinox Business Park, LBS Marg, Kurla West, Mumbai - 400070, India

Tel: +91 22 41711700 CIN: L99999MH1922PLC000987

G	Alternator Specification	
1	Alternator Make	CG
2	Alternator kVA Rating	10
3	Voltage (1P/3P)	230 / 415
4	Frequency (Hz)	50
5	Current (1P/3P) (Amps)	43.47 / 13.91
6	Type	4P, rotating field
7	Voltage regulator	Solid state
8	Voltage regulation -%	±1%
9	Insulation class	H
10	Temperature rise (Deg C)	125
11	Bearing (Qty / type)	1, sealed
12	Coupling	Conical Shaft
13	Unbalanced load capability	25% of rated amps
H	Cooling System	
1	Max ambient capability (Deg C)	50
2	Coolant capacity (Eng + Rad) (L)	7.5
I	Controller	
1	Controller Model (DIEF)	SGC 120 MKII
J	DEF System	
1	Recommended fuel	NA
2	DEF Tank Capacity (L)	NA
K	DEF Consumption	
1	LPH @ 100%	NA
2	LPH @ 75%	NA
L	Genset Outer Dimensions	
1	Length(L) X Width(W) X Height(H) (mm)	1420(L) (L-1912 Including Ducts) X 930 X 1285
2	Dry Weight (Approx.) (kg)	590
	Disclaimer:	
	- Ref.: ⁽¹⁾Fuel consumption @ 0.85 Specific Gravity with 5% Tolerance, DEF consumption: 5% of FC - PRIME POWER RATING as per ISO 8528-Part I - Conformance standards: Engine - BS 5514, ISO 3046, Alternator - IS 13364 (I) - Genset - ISO 8528 and Tolerances as applicable. Please refer to our GA drawing for overall dimension with add on components like silencer, ducts etc. - Product specifications are subject to change without prior notice due to the policy of continuous improvement. - This Product comply to CPCBIV+ Emission Norms.	

GREAVES COTTON LIMITED

Email ID: info@greavescotton.com Website: www.greavescotton.com

Registered Office: J-2, MIDC Industrial Area, Chikalthana, Aurangabad - 431210, India

Corporate Office: Unit No.1A, 5th Floor, Tower 3, Equinox Business Park, LBS Marg, Kurla West, Mumbai - 400070, India

Tel: +91 22 41711700 CIN: L99999MH1922PLC000987