

Sr. No.	Genset Rated →	200kVA - Mech	200kVA - CRDI
A	Genset specification ↓		
1	Genset rating	Prime	Prime
2	Genset output (kVA/kWe)	200 / 160	200 / 160
3	Genset model	GPWII-PIV-200M	GPWII-PIV-200C
4	Gross engine Power (kWm)	178.8	178.8
5	Gross engine Power (HP)	243.3	243.3
6	Engine model	6G11TAG31	6G11TAG42
7	Aspiration / Cooling	TCAC	TCAC
8	No. of Cylinders / Arrangement	6 / inline	6 / inline
9	Displacement (L)	7.31	7.31
10	Bore x Stroke (mm)	108 X 133	108 X 133
11	Compression ratio	16.8	16.8
12	Rated RPM	1500	1500
13	Overspeed trip (RPM)	1650	1650
14	Governor type / DG Performance Class	Elec / G3	CRS / G3
15	Frequency Regulation	Isochronous	Isochronous
16	Air cleaner type / Qty	Dry / 01	Dry / 01
B	Exhaust system		
1	Max allowable backpressure before After-treatment (kPa)	13	13
2	Max allowable backpressure post After-treatment (kPa)	5	5
3	Exhaust temperature (Deg C)	530	530
4	Silencer type	NA	NA
5	Aftertreatment System	DOC+SCR+ASC	DOC+SCR+ASC
C	Engine electrical system		
1	Charging alternator VDC / Amps	12 V / 35 A	12 V / 35 A
2	Starter motor rated voltage (DC)	12	12
3	Battery voltage (DC) / Capacity (AH)	12V / 130 AH	12V / 130 AH
D	Fuel System		
1	Recommended fuel	IS 1460, HSD	IS 1460, HSD
2	Fuel tank capacity (L)	320	320
E	Fuel Consumption @ % load (LPH)(Including radiator fan + other accessories)⁽¹⁾		
1	LPH @ 100%	44.30	42.00
2	LPH @ 75%	33.00	31.50
F	Lubricating Oil System		
1	Lube oil sump capacity (L)	17.5	17.5
2	Lube oil change period (Hrs)	500	500
3	Lube oil consumption (% of SFC)	≤0.06%	≤0.06%
4	Lube oil filter type / Qty	Spin on / 01	Spin on / 01
5	Recommended lube oil grade	15W40, API CI4+	15W40, API CI4+
6	Recommended lube oil	Greaves Maxtherm	Greaves Maxtherm

GREAVES COTTON LIMITED

Email ID: info@greavescotton.com Website: www.greavescotton.com

Registered Office: J-2, MIDC Industrial Area, Chikalthana, Aurangabad - 431210, India

Corporate Office: Unit No.1A, 5th Floor, Tower 3, Equinox Business Park, LBS Marg, Kurla West, Mumbai - 400070, India

Tel: +91 22 41711700 CIN: L99999MH1922PLC000987

G	Alternator Specification		
1	Alternator Make	CG	CG
2	Alternator kVA/KW	200 / 160	200 / 160
3	Voltage (3P)	415	415
4	Frequency (Hz)	50	50
5	Current (3P) (Amps)	278.24	278.24
6	Type	4P, rotating field	4P, rotating field
7	Voltage regulator	Automatic	Automatic
8	Voltage regulation -%	±1%	±1%
9	Insulation class	H	H
10	Temperature rise (Deg C)	125	125
11	Bearing (Qty / type)	1, sealed	1, sealed
12	Coupling	Flex disc	Flex disc
13	Unbalanced load capability	25% of rated amps	25% of rated amps
H	Cooling System		
1	Max ambient capability (Deg C)	50	50
2	Coolant capacity (Eng + Rad) (L)	35	35
I	Controller		
1	Controller Model	DSE 6120 MKIII	DSE 6120 MKIII
J	DEF System		
1	Recommended fuel	ISO 22241, DIN-70070	ISO 22241, DIN-70070
2	DEF Tank Capacity (L)	40	40
K	DEF Consumption		
1	LPH @ 100%	2.2	2.1
2	LPH @ 75%	1.7	1.6
L	Genset Outer Dimensions		
1	Length(L) X Width(W) X Height(H) (mm)	4300 x 1600 x 2250	4300 x 1600 x 2250
2	Dry Weight (Approx.) (kg)	2250	2250
	Disclaimer:		
	1. Ref.: ⁽¹⁾ Fuel consumption @ 0.85 Specific Gravity with 5% Tolerance, DEF consumption : 5% of FC 2. PRIME POWER RATING as per ISO 8528 3. Conformance standards: Engine - BS 5514, ISO 3046, Alternator - IS 13364 (Part - II), Genset - ISO 8528 and Tolerances as applicable. Please refer our GA drawing for overall dimension with add on components like silencer, ducts etc. 4. Product specifications are subject to change without prior notice due to the policy of continuous improvement. 5. Others make alternator also available – Please consult application engineering department 6. DG complying CPCBIV+ norms		

GREAVES COTTON LIMITED

 Email ID: info@greavescotton.com Website: www.greavescotton.com

Registered Office: J-2, MIDC Industrial Area, Chikalthana, Aurangabad - 431210, India

 Corporate Office: Unit No.1A, 5th Floor, Tower 3, Equinox Business Park, LBS Marg, Kurla West, Mumbai - 400070, India

Tel: +91 22 41711700 CIN: L99999MH1922PLC000987

GREAVES COTTON LIMITED

Email ID: info@greavescotton.com **Website:** www.greavescotton.com

Registered Office: J-2, MIDC Industrial Area, Chikalthana, Aurangabad - 431210, India

Corporate Office: Unit No.1A, 5th Floor, Tower 3, Equinox Business Park, LBS Marg, Kurla West, Mumbai - 400070, India

Tel: +91 22 41711700 **CIN:** L99999MH1922PLC000987